



OFFICE OF THE ASSISTANT FIRE OFFICER,  
FIRE STATION, BHUBANESWAR.

No: 3390/BBSRF.S.

Dt. 07/10/2017

To

The Executive Director  
ST. Xavier's High School  
V.S.S Nagar Bhubaneswar

Ref:- Your Letter No.48/SXHS Dated.Nil

Sub:- Report relevant to Fire and Life Safety arrangement at ST. Xavier's High School, V.S.S Nagar, Bhubaneswar.

Dear Sir,

Your School was inspected from fire Safety point of view in your presence. The observations are as under.


That the occupancy is functioning in G+2<sup>nd</sup> Storied Building having no class room (Teaching arrangement) functioning in 2<sup>nd</sup> Floor. The following fire protection measures are available in the School.


1. ABC Type Extinguishers-6Kg-10Nos
2. Co2 Type Extinguishers-4.5Kg -5Nos

The above Fire Protection measures were randomly test checked and found in a functional condition.

Suggestion to be adhered in view of life safety:-


1. That the occupancy shall not be used for the other purpose.
2. That the set back as per approved plan needs to be provided.
3. Mock drills have to be practiced annually twice.
4. The management should maintain good housekeeping to avoid fire hazard.
5. That the life and fire safety arrangement shall be made with the National Building Code of India-2016

  
EXECUTIVE DIRECTOR  
ST. XAVIER'S HIGH SCHOOL  
V.S.S. NAGAR BBSR

  
Principal  
ST. XAVIER'S HIGH SCHOOL  
V.S.S. Nagar

Therefore you will please adhere the above suggestions and provide necessary fire safety measures in your occupancy within Six months from the date of issue of this letter and intimate necessary compliance. Now the functional aspect of the building is suitable for the occupancy.

Yours' faithfully,



Assistant Fire Officer,  
Fire Station, Bhubaneswar.  
**Asst. Fire Officer**  
Fire Station, Bhubaneswar

Memo No. \_\_\_\_\_/BBSR FS

Dated.

Copy submitted to the DCP, Bhubaneswar For favour of kind information and necessary action please.



Assistant Fire Officer,  
Fire Station, Bhubaneswar.  
**Asst. Fire Officer**  
Fire Station, Bhubaneswar

